

CONSENT NO: 186/06

FILE NO: TC 344/05

DEPARTMENT OF THE ENVIRONMENT

Water (Northern Ireland) Order 1999

Consent to Discharge of Effluent

TO:



The Department of the Environment in pursuance of the powers conferred on it by the Water (Northern Ireland) Order 1999 HEREBY CONSENTS to your making a discharge into a waterway at Irish Grid Reference H 6766 8005 in accordance with the application dated 6 September 2005 in respect of a discharge of site drainage from a waste transfer station at 324 Drum Road, Cookstown, Co Tyrone, BT80 9PS.

SUBJECT TO the following conditions:

1. The effluent discharged shall not:

- a) have a biochemical oxygen demand in excess of 10 milligrammes per litre;
- b) have suspended solids in excess of 50 milligrammes per litre;
- c) have a pH value less than 6 nor greater than 9;
- d) contain visible oil or grease;
- e) contain any substance (other than as defined above) which will cause the waterway or water in an underground stratum to be toxic or injurious to fish or other aquatic organisms.

CONSENT NO: 186/06

FILE NO: TC 344/05

DEPARTMENT OF THE ENVIRONMENT

Water (Northern Ireland) Order 1999

Consent to Discharge of Effluent

2. Facilities:

- a) shall be available at a purpose built point at the outfall for sampling the final discharge, the consent holder shall maintain and label the facilities to ensure that a representative sample of the discharge can be obtained;
- b) the sample point will be at the point indicated on the current site map provided to the Department;
- c) the sample point for this discharge shall be maintained so that it is freely available and accessible to authorised officers of the Department;
- d) authorised officers of the Department shall be allowed to readily and safely obtain a sample of the effluent, measurement of flow, images of discharge or other data relative to the discharge at all times.

CONSENT NO:186/06

FILE NO: TC344/05

DEPARTMENT OF THE ENVIRONMENT

Water (Northern Ireland) Order 1999


Consent to Discharge of Effluent

3. Other conditions

- a) the treatment system shall be maintained in order that Conditions of Discharge can be met at all times;
- b) bunds should be provided around any oil or chemical storage tanks on the premises to reduce the risk of pollution from accidental spillage or leakage;
- c) any storage of unusual or dangerous substances shall be notified immediately to the Department;
- d) any change of process, or introduction of new process chemicals shall be notified immediately to the Department.

Dated this 20 day of May 2006

***Environment and Heritage Service
Water Management Unit
Calvert House
23 Castle Place
BELFAST
BT1 1FY***



TC48/04

~~TC42/C4~~

DEPARTMENT OF THE ENVIRONMENT

ing and 3000 20
B/A/N T E L

at to Conditions (if any)
out on


Decision made on 1/97/0482
15.3.99

Entrance into
waste recycling facility

To Cookstown E

Drum Rd

ownship



Northern
Embankment

Access Road

Offices / Bio - filter:


Eastern Embankment

Silt Mound

Proposed
Building

KLAROSSE TANK

DEPARTMENT OF THE ENVIRONMENT



Silt Ponds

Southern Embankment

Western Embankment

Proposed Chain Link fence
creating a physical barrier
between both operations

Quarry area
presently in use

Chain Link Fence

Development Site Boundary

Scale 1:2500

The Planning Service
RECEIVED
17 NOV 1998
File No. Headquarters

APPENDIX 2

Separate entrance into
quarry from Lough Doo Road.

